



NOTES:

1. FACTORY INSTALLED INSULATION: HYDROUS CALCIUM SILICATE, MAXIMUM TEMP. IS 1200° F, K FACTOR = 0.31 @ 75°F.
2. PIPE GUIDE MATL: CARBON STEEL WITH BLACK PAINT FINISH.
3. BODY NO. 29 & UP ARE SUPPLIED WITH 4 BOLTS.

KEFLEX PRODUCTS 1425 LAKE AVENUE WOODSTOCK, ILLINOIS 60098			
TITLE		1 OF 2	
CP SERIES PIPE ALIGNMENT GUIDE			
PRE-INSULATED GUIDE			
SIZE	FSCM NO.	DWG NO.	REV
A	87738	SUBMITTAL DRAWING	B
DRAWN DG	DATE 8 JAN 01	FILE SUBPISG1.DWG	

SUBMITTED BY	DATE	CLIENT APPROVAL	DATE

NOM PIPE SIZE	INSULATION THICKNESS			
	1 1/2"	2"	3"	4"
1/2	F004CP25014	F004CP26020	F004CP27030	F004CP28040
3/4	F006CP25014	F006CP26020	F006CP27030	F006CP28040
1	F010CP25014	F010CP26020	F010CP27030	F010CP28040
1 1/4	F012CP26014	F012CP26020	F012CP27030	F012CP28040
1 1/2	F014CP26014	F014CP26020	F014CP27030	F014CP28040
2	F020CP26014	F020CP27020	F020CP28030	F020CP28040
2 1/2	F024CP26014	F024CP27020	F024CP28030	F024CP29040
3	F030CP27014	F030CP27020	F030CP28030	F030CP29040
4	F040CP27014	F040CP28020	F040CP29030	F040CP30040
5	F050CP28014	F050CP28020	F050CP29030	F050CP30040
6	F060CP28014	F060CP29020	F060CP30030	F060CP31040
8	F080CP29014	F080CP30020	F080CP31030	F080CP32040
10	F100CP31014	F100CP31020	F100CP32030	F100CP33040
12	F120CP32014	F120CP32020	F120CP33030	F120CP34040
14	F140CP32014	F140CP33020	F140CP34030	F140CP35040
16	F160CP33014	F160CP34020	F160CP35030	F160CP36040
18	F180CP34014	F180CP35020	F180CP36030	F180CP36040

BODY NO.	WT. # EA.	DIMENSION IN INCHES						
		H	R	W	Y	B	C	L
25	10	7 5/8	4 3/8	8 1/8	5 1/8	5/8	1 3/4	3
26	13	9 1/4	5 1/4	10 1/8	6 1/8	5/8	1 3/4	3
27	20	11 5/8	6 1/4	12 1/8	7	5/8	2 3/4	4
28	25	13 3/8	7	14 1/8	8 1/4	5/8	2 3/4	4
29	40	15 1/8	7 7/8	16 1/8	9 7/8	3/4	4	6
30	45	17	8 7/8	18 1/8	10 7/8	3/4	4	6
31	55	18 3/4	9 3/4	20 1/8	11 7/8	3/4	4	6
32	65	21	10 7/8	22 1/8	11 3/4	3/4	4	6
33	95	23 1/8	12 1/8	24 1/8	14 1/2	7/8	6	8
34	100	25	13	26 1/8	15 1/2	7/8	6	8
35	120	27 3/4	14 3/4	28 1/8	17 1/8	1 1/8	6	8
36	150	31 1/2	16 1/2	32 1/8	19 1/4	1 1/8	6	8
-	-	-	-	-	-	-	-	-

KEFLEX PRODUCTS 1425 LAKE AVENUE WOODSTOCK, ILLINOIS 60098			
TITLE			
CP SERIES PIPE ALIGNMENT GUIDE PRE-INSULATED GUIDE			2 OF 2
SIZE	FSCM NO.	DWG NO.	REV
A	87738	SUBMITTAL DRAWING	B
DRAWN DG		DATE 8 JAN 01	FILE SUBPISG2.DWG

SUBMITTED BY	DATE	CLIENT APPROVAL	DATE
--------------	------	-----------------	------