

NOM PIPE	INSULATION THICKNESS										
SIZE	0 -1"	1 1/2"	2"	2 1/2"	3"	3 1/2"	4"				
1/2	F004P23	F004P23	F004P24	F004P25	F004P26	F004P26	F004P27				
3/4	F006P23	F006P24	F006P25	F006P26	F006P26	F006P27	F006P27				
1	F010P23	F010P24	F010P25	F010P26	F010P26	F010P27	F010P27				
1 1/4	F012P23	F012P24	F012P25	F012P26	F012P26	F012P27	F012P27				
1 1/2	F014P24	F014P24	F014P25	F014P26	F014P26	F014P27	F014P27				
2	F020P24	F020P25	F020P26	F020P26	F020P27	F020P27	F020P28				
2 1/2	F024P25	F024P25	F024P26	F024P26	F024P27	F024P27	F024P28				
3	F030P25	F030P26	F030P26	F030P27	F030P27	F030P28	F030P28				
4	F040P26	F040P26	F040P27	F040P27	F040P28	F040P28	F040P29				
5	F050P27	F050P27	F050P27	F050P28	F050P28	F050P29	F050P30				
6	F060P27	F060P27	F060P28	F060P28	F060P29	F060P30	F060P30				
8	F080P28	F080P28	F080P29	F080P30	F080P30	F080P31	F080P31				
10	F100P30	F100P30	F100P30	F100P31	F100P31	F100P32	F100P32				
12	F120P31	F120P31	F120P31	F120P32	F120P32	F120P33	F120P33				
14	F140P32	F140P32	F140P32	F140P32	F140P33	F140P33	F140P3/4				
16	F160P33	F160P33	F160P33	F160P33	F160P34	F160P34	F160P35				
18	F180P34	F180P34	F180P34	F180P34	F180P35	F180P35	F180P36				
20	F200P35	F200P35	F200P35	F200P35	F200P36	F200P36	F200P36				
24	F240P36	F240P36	F240P36	F240P36		_					

MOVEMENT

	ř							•	TALL OF	WADLE
BODY	WT.	DIMENSION IN INCHES							1	VABLE MOVEI
NO.	# EA.	Н	R	W	Y	В	С	L	AXIAL	MUVEI
23	7	5 7/8	3 1/2	6 1/8	4 1/8	5/8	1 3/4	3	4	
24	8	6 3/4	4	7 1/8	4 3/8	5/8	1 3/4	3	4	
25	9	7 5/8	4 3/8	8 1/8	5 1/8	5/8	1 3/4	3	4	
26	11	9 1/4	5 1/4	10 1/8	6 1/8	5/8	1 3/4	3	4	
27	17	11 5/8	6 1/4	12 1/8	7	5/8	2 3/4	4	4	
28	20	13 3/8	7	14 1/8	8 1/4	5/8	2 3/4		4	
29	40	15 1/8	7 7/8	16 1/8	9 7/8	3/4	4	6	6	
30	48	17	8 7/8	18 1/8	10 7/8	3/4	4	6	6	
31	54	18 3/4	9 3/4	20 1/8	11 7/8	3/4	4	6	6	
32	61	21	10 7/8	22 1/8	11 3/4	3/4	4	6	6	
33	89	23 1/8	12 1/8	24 1/8	14 1/2	7/8	6	8	8	
34	102	25	13	26 1/8	15 1/2	7/8	6	8	8	
35	110	27 3/4	14 3/4	28 1/8	17 1/8	1 1/8	6	8	8	TITLE
36	150	31 1/2	16 1/2	32 1/8	19 1/4	1 1/8	6	8	8	
_	_	-	_	_		_	_	-	_	
								•		

## KEFLEX PRODUCTS 1425 LAKE AVENUE WOODSTOCK, ILLINOIS 60098

P SERIES PIPE ALIGNMENT GUIDE
NON-INSULATED GUIDE

DATE 8 JAN 01

2 OF 2

SIZE | FSCM NO. | 87738

DRAWN DG

DWG NO.
SUBMITTAL DRAWING

REV

SUBMITTED BY

DATE

CLIENT APPROVAL

DATE

FILE SUBSSG2.DWG